



CCIC Southern Testing Co., Ltd.

Attestation Of Conformity

CERTIFICATE NO.: SET2020-00162

Product: PV Grid Inverter

Model: MID 25KTL3-X

Applicant: Shenzhen Growatt New Energy Technology Co., LTD

Address: 1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28,
GuangHui Road, LongTeng Community, Shiyan Street, Baoan District,
Shenzhen, P.R.China

This is to certify that, on the basis of the tests undertaken as per Report No. **SET2019-17174**, the submitted sample of the above item complies with:

EN 61000-6-2:2005
EN 61000-6-3:2007+A1:2011

and fulfils testing requirement of the EMC directive 2014/30/EU



Note: The model MID 10KTL3-X/ MID 12KTL3-X/ MID 15KTL3-X/ MID 17KTL3-X/ MID 20KTL3-X/ MID 22KTL3-X/ MID 25KTL3-X the difference as below: same appearance and structure, the control circuits and power circuit have same schemem, different only in electrical rating and voltage sampling circuit.

Signed for and on behalf of

CCIC Southern Testing Co., Ltd.

Zhao Yan Ni

Date of Issue: Jan. 07, 2020

Zhao Yan Ni, Vice Director

CCIC Southern Testing Co., Ltd.

Electronic Testing Building, No. 43 Shahe Road, Xili Street, Nanshan District,

Shenzhen, 518055, P. R. China

Tel:86-0755-26627338 Fax:86-0755-26627238 <http://www.ccic-set.com>