



TL-395

Test Report issued under the responsibility of:



Total Quality. Assured.

TEST REPORT
IEC 61727
Photovoltaic (PV) systems –
Characteristics of the utility interface

Report Number : 220308046GZU-001

Date of issue : 30 May 2022

Total number of pages : 26 Pages

Name of Testing Laboratory preparing the Report : Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of
Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD,
Guangzhou, Guangdong, China

Applicant's name : Shenzhen Growatt New Energy Co., Ltd.

Address : 4-13/F, Building A, Sino-German (Europe) Industrial Park,
Hangcheng Ave, Bao'an District, Shenzhen, China

Test specification:

Standard : IEC 61727:2004

Test procedure : Type approval

Non-standard test method : N/A

Test Report Form No. : IEC61727B

Test Report Form(s) Originator : TÜV SÜD Product Service GmbH

Master TRF : Dated 2017-11-03

Copyright © 2017 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description . :	PV Grid inverter					
Trade Mark	GROWATT					
Manufacturer.....	Same as applicant					
Model/Type reference :	MAX 50KTL3-XL2, MAX 60KTL3-XL2, MAX 70KTL3-XL2, MAX 73KTL3-XL2 MAX 75KTL3-XL2, MAX 50KTL3-XL1, MAX 60KTL3-XL1, MAX 70KTL3-XL1, MAX 73KTL3-XL1, MAX 75KTL3-XL1					
Ratings	Model	MAX 50KTL3- XL2	MAX 60KTL3- XL2	MAX 70KTL3- XL2	MAX 73KTL3- XL2	MAX 75KTL3- XL2
	Max.PV voltage	1100Vdc				
	MPPT voltage	180-850Vdc				
	Max.input current	8*45A				
	PV Isc	8*56.5A				
	Nominal output voltage	3W/N/PE, 127/220Vac				
	Nominal output Frequency	50/60Hz				
	Max.output current	144.3A	173.2A	183.7A	191.6A	196.9A
	Max. output power	50KW	60KW	70KW	73KW	75KW
	Max. apparent power	55KVA	66KVA	70KVA	73KVA	75KVA
	Power factor range	0.8Leading~0.8Lagging				
	Safety level	Class I				
	Ingress Protection	IP 66				
	Operation Ambient Temperature	-30°C - +60°C				
	Software version	TN1.0				
	Model	MAX 50KTL3- XL1	MAX 60KTL3- XL1	MAX 70KTL3- XL1	MAX 73KTL3- XL1	MAX 75KTL3- XL1





Max.PV voltage	1100Vdc				
MPPT voltage	180-850Vdc				
Max.input current	10*32A				
PV Isc	10*40A				
Nominal output voltage	3W/N/PE, 127/220Vac				
Nominal output Frequency	50/60Hz				
Max.output current	144.3A	173.2A	183.7A	191.6A	196.9A
Max. output power	50KW	60KW	70KW	73KW	75KW
Max. apparent power	55KVA	66KVA	70KVA	73KVA	75KVA
Power factor range	0.8Leading~0.8Lagging				
Safety level	Class I				
Ingress Protection	IP 66				
Operation Ambient Temperature	-30°C - +60°C				
Software version	TN1.0				

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	Testing Laboratory:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Testing location/ address.....:		Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China
<input type="checkbox"/>	Associated CB Testing Laboratory:	N/A
Testing location/ address.....:		N/A
Tested by (name, function, signature).....:		Joss Huang Engineer <i>Joss Huang.</i>
Approved by (name, function, signature)....:		Jason Fu Supervisor <i>Jason Fu</i>
<input type="checkbox"/>	Testing procedure: TMP/CTF Stage 1:	N/A
Testing location/ address.....:		N/A
Tested by (name, function, signature).....:		N/A
Approved by (name, function, signature)....:		N/A
<input type="checkbox"/>	Testing procedure: WMT/CTF Stage 2:	N/A
Testing location/ address.....:		N/A
Tested by (name + signature)		N/A
Witnessed by (name, function, signature) .:		N/A
Approved by (name, function, signature)....:		N/A
<input type="checkbox"/>	Testing procedure: SMT/CTF Stage 3 or 4:	N/A
Testing location/ address.....:		N/A
Tested by (name, function, signature).....:		N/A
Witnessed by (name, function, signature) .:		N/A
Approved by (name, function, signature)....:		N/A
Supervised by (name, function, signature) :		N/A

List of Attachments (including a total number of pages in each attachment): Appendix 1: photos (3 pages)	
Summary of testing:	
Tests performed (name of test and test clause): All applicable tests	Testing location: Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China
Summary of compliance with National Differences: List of countries addressed N/A	
<input checked="" type="checkbox"/> The product fulfils the requirements of IEC 61727:2004	

Copy of marking plate:

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.

 PV Grid Inverter		 PV Grid Inverter	
Model name	MAX 75KTL3-XL1	Model name	MAX 75KTL3-XL2
Max. PV voltage	1100 d.c.V	Max. PV voltage	1100 d.c.V
PV voltage range	180-850 d.c.V	PV voltage range	180-850 d.c.V
PV Isc	32 d.c.A*10	PV Isc	56.5 d.c.A*8
Max. input current	40 d.c.A*10	Max. input current	45 d.c.A*8
Max. output power	75 kW	Max. output power	75 kW
Max. apparent power	75 kVA	Max. apparent power	75 kVA
Nominal output voltage	3W/N/PE 127/220 a.c.V	Nominal output voltage	3W/N/PE 127/220 a.c.V
Max. output current	196.9 a.c.A	Max. output current	196.9 a.c.A
Nominal output frequency	50/60 Hz	Nominal output frequency	50/60 Hz
Power factor range	0.8leading~0.8lagging	Power factor range	0.8leading~0.8lagging
Safety level	Class I	Safety level	Class I
Ingress protection	IP66	Ingress protection	IP66
Operation ambient temperature	-30°C ~ +60°C	Operation ambient temperature	-30°C ~ +60°C
VDE0126-1-1  Made in China		VDE0126-1-1  Made in China	

Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation.
3. Other labels are identical to above, except the model's name and ratings

Test item particulars.....:	
Classification of installation and use.....: Fixed and outdoor use	
Supply Connection Permanent connection	
.....:	
Possible test case verdicts:	
- test case does not apply to the test object.....: N/A	
- test object does meet the requirement.....: P (Pass)	
- test object does not meet the requirement.....: F (Fail)	
Testing.....:	
Date of receipt of test item 06 April 2022	
Date (s) of performance of tests 06 April 2022 to 10 May 2022	
General remarks:	
<p>"(See Enclosure #)" refers to additional information appended to the report.</p> <p>"(See appended table)" refers to a table appended to the report.</p> <p>Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.</p> <p>Determination of the test conclusion is based on IEC Guide 115 in consideration of measurement uncertainty.</p> <p>This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.</p> <p>The test report only allows to be revised only within the report defined retention period unless standard or regulation was withdrawn or invalid.</p> <p>This report shall be used together with the report 220308046GZU-002.</p>	
Manufacturer's Declaration per sub-clause 4.2.5 of IECCE 02:	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided :	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable
When differences exist; they shall be identified in the General product information section.	
Name and address of factory (ies) Guangdong Growatt New Energy Co., Ltd. Growatt Industrial Park, No.17 Pingheng Road Pingtan Town, Huiyang District, Huizhou, Guangdong, China	

General product information:

The unit is a three-phase PV Grid inverter, it can convert the high PV voltage to Grid voltage and feed into Grid network.

The unit is providing EMC filtering at the PV side and AC side. It is transformerless between the PV circuit and AC circuit.


The unit has three controllers. The master controller DSP A measure the PV voltage and current, AFCI, PV ISO and also communicate with the slave controller B and slave controller ARM and etc; The slave controller DSP B is used to INV control and PV ISO measurement and etc.

The slave controller ARM monitor AC voltage, GFCI and communicate with the master controller DSP

The relays are designed to redundant structure that controlled by separately.

The master controller A and slave controller B are used together to control relay open or close, if the single fault on one controller, the other controller can be capable to open the relay, so that still providing safety means.

The topology diagram as following:



Difference of models:

All models are identical, except the number of MPPT and the output power derating in software.

Other than special notice, the model MAX 75KTL3-XL2 is as the representative test model in this report.

IEC61727			
Cl.	Requirement - Test	Result	Verdict
4	UTILITY COMPATIBILITY		P
	The quality of power provided by the PV system for the on-site AC loads and for power delivered to the utility is governed by practices and standards on voltage, flicker, frequency, harmonics and power factor.		P
	Deviation from these standards represents out-of-bounds conditions and may require the PV system to sense the deviation and properly disconnect from the utility system.		P
4.1	Voltage, current and frequency		P
	The PV system AC voltage, current and frequency are compatible with the utility system.		P
4.2	Normal voltage operating range		P
	Utility-interconnected PV systems do not normally regulate voltage, they inject current into the utility. Therefore, the voltage operating range for PV inverters is selected as a protection function that responds to abnormal utility conditions, not as a voltage regulation function.		P
4.3	Flicker		P
	The operation of the PV system is not cause voltage flicker in excess of limits stated in the relevant sections of IEC 61000-3-3 for systems less than 16 A or IEC 61000-3-5 for systems with current of 16 A and above.		P
4.4	DC injection		P
	The PV system is not inject DC current greater than 1 % of the rated inverter output current, into the utility AC interface under any operating condition.	(See appended table)	P
4.5	Normal frequency operating range		P
	The PV system operates in synchronism with the utility system, and within the frequency trip limits defined in 5.2.2.		P
4.6	Harmonics and waveform distortion		P
	Total harmonic current distortion is less than 5 % at rated inverter output. Each individual harmonic is limited to the percentages listed in Table 1.	(See appended table)	P
	Even harmonics in these ranges is less than 25 % of the lower odd harmonic limits listed.		P

IEC61727																					
Cl.	Requirement - Test	Result	Verdict																		
	<table><tr><th colspan="2">Table 1 – Current distortion limits</th></tr><tr><th>Odd harmonics</th><th>Distortion limit</th></tr><tr><td>3rd through 9th</td><td>Less than 4,0 %</td></tr><tr><td>11th through 15th</td><td>Less than 2,0 %</td></tr><tr><td>17th through 21st</td><td>Less than 1,5 %</td></tr><tr><td>23rd through 33rd</td><td>Less than 0,6 %</td></tr><tr><th>Even harmonics</th><th>Distortion limit</th></tr><tr><td>2rd through 8th</td><td>Less than 1,0 %</td></tr><tr><td>10th through 32nd</td><td>Less than 0,5 %</td></tr></table>	Table 1 – Current distortion limits		Odd harmonics	Distortion limit	3 rd through 9 th	Less than 4,0 %	11 th through 15 th	Less than 2,0 %	17 th through 21 st	Less than 1,5 %	23 rd through 33 rd	Less than 0,6 %	Even harmonics	Distortion limit	2 rd through 8 th	Less than 1,0 %	10 th through 32 nd	Less than 0,5 %		P
Table 1 – Current distortion limits																					
Odd harmonics	Distortion limit																				
3 rd through 9 th	Less than 4,0 %																				
11 th through 15 th	Less than 2,0 %																				
17 th through 21 st	Less than 1,5 %																				
23 rd through 33 rd	Less than 0,6 %																				
Even harmonics	Distortion limit																				
2 rd through 8 th	Less than 1,0 %																				
10 th through 32 nd	Less than 0,5 %																				
4.7	The PV system has a lagging power factor greater than 0,9 when the output is greater than 50 % of the rated inverter output power.		P																		
5	PERSONNEL SAFETY AND EQUIPMENT PROTECTION		P																		
	This Clause provides information and considerations for the safe and proper operation of the utility-connected PV systems.		P																		
5.1	Loss of utility voltage		P																		
	To prevent islanding, a utility connected PV system ceases to energize the utility system from a de-energized distribution line irrespective of connected loads or other generators within specified time limits.	Complied with IEC 62116, See the separate report for reference	P																		
	A utility distribution line can become de-energized for several reasons. For example, a substation breaker opening due to fault conditions or the distribution line switched out during maintenance.		P																		
5.2	Over/under voltage and frequency		P																		
	The abnormal utility conditions of concern are voltage and frequency excursions above or below the values stated in this Clause, and the complete disconnection of the utility, presenting the potential for a distributed resource island.		P																		
5.2.1	Over/under voltage		P																		
	When the interface voltage deviates outside the conditions specified in Table 2, the photovoltaic system ceases to energize the utility distribution system. This applies to any phase of a multiphase system.	(See appended table)	P																		

IEC61727																			
Cl.	Requirement - Test	Result	Verdict																
	<table><tr><th colspan="2">Table 2 – Response to abnormal voltages</th></tr><tr><th>Voltage (at point of utility connection)</th><th>Maximum trip time*</th></tr><tr><td>$V < 0,5 \times V_{\text{nominal}}$</td><td>0,1 s</td></tr><tr><td>$50 \% \leq V < 85 \%$</td><td>2,0 s</td></tr><tr><td>$85 \% \leq V \leq 110 \%$</td><td>Continuous operation</td></tr><tr><td>$110 \% < V < 135 \%$</td><td>2,0 s</td></tr><tr><td>$135 \% \leq V$</td><td>0,05 s</td></tr><tr><td colspan="2">* Trip time refers to the time between the abnormal condition occurring and the inverter ceasing to energize the utility line. The PV system control circuits shall actually remain connected to the utility to allow sensing of utility electrical conditions for use by the "reconnect" feature.</td></tr></table>	Table 2 – Response to abnormal voltages		Voltage (at point of utility connection)	Maximum trip time*	$V < 0,5 \times V_{\text{nominal}}$	0,1 s	$50 \% \leq V < 85 \%$	2,0 s	$85 \% \leq V \leq 110 \%$	Continuous operation	$110 \% < V < 135 \%$	2,0 s	$135 \% \leq V$	0,05 s	* Trip time refers to the time between the abnormal condition occurring and the inverter ceasing to energize the utility line. The PV system control circuits shall actually remain connected to the utility to allow sensing of utility electrical conditions for use by the "reconnect" feature.			P
Table 2 – Response to abnormal voltages																			
Voltage (at point of utility connection)	Maximum trip time*																		
$V < 0,5 \times V_{\text{nominal}}$	0,1 s																		
$50 \% \leq V < 85 \%$	2,0 s																		
$85 \% \leq V \leq 110 \%$	Continuous operation																		
$110 \% < V < 135 \%$	2,0 s																		
$135 \% \leq V$	0,05 s																		
* Trip time refers to the time between the abnormal condition occurring and the inverter ceasing to energize the utility line. The PV system control circuits shall actually remain connected to the utility to allow sensing of utility electrical conditions for use by the "reconnect" feature.																			
5.2.2	Over/under frequency		P																
	When the utility frequency deviates outside the specified conditions the photovoltaic system ceases to energize the utility line. The unit does not have to cease to energize if the frequency returns to the normal utility continuous operation condition within the specified trip time.	(See appended table)	P																
	When the utility frequency is outside the range of ± 1 Hz, the system ceases to energize the utility line within 0,2 s. The purpose of the allowed range and time delay is to allow continued operation for short-term disturbances and to avoid excessive nuisance tripping in weak-utility system conditions.		P																
5.3	Islanding protection		P																
	The PV system must cease to energize the utility line within 2 s of loss of utility.		P																
5.4	Response to utility recovery		P																
	Following an out-of-range utility condition that has caused the photovoltaic system to cease energizing, the photovoltaic system is not energize the utility line for 20 s to 5 min after the utility service voltage and frequency have recovered to within the specified ranges.	(See appended table)	P																
5.5	Earthing		P																
	The utility interface equipment is earthed/grounded in accordance with IEC 60364-7-712.		P																
5.6	Short circuit protection		N/A																
	The photovoltaic system has short-circuit protection in accordance with IEC 60364-7-712.	Should consider in the end use	N/A																
5.7	Isolation and switching		N/A																
	A method of isolation and switching is provided in accordance with IEC 60364-7-712.	Should consider in the end use	N/A																

IEC61727			
Cl.	Requirement - Test	Result	Verdict

4.3	TABLE: Flicker				P
Model: MAX 75KTL3-XL2					
	Starting	Stopping	Running		
Limit	4%	4%	Pst = 1.0	Plt = 0.65	
Test value L1-N	1.61	2.99	0.58	0.54	
Test value L2-N	0.73	2.86	0.59	0.55	
Test value L3-N	1.56	2.97	0.59	0.55	
Supplementary information:					

4.4	TABLE: Direct current injection								P
Rated output current (A)	Ratio of rated output power (VA)	Measured DC output current between terminals						Isolated transformer ? (Yes/No)	Limit (mA)
		L1-L2 (mA)	L1-L3 (mA)	L2-L3 (mA)	L1-N (mA)	L2-N (mA)	L3-N (mA)		
Model: MAX 75KTL3-XL2									
196.9	25%	--	--	--	215.7	109.0	120.0	No	1969
196.9	50%	--	--	--	152.4	129.9	109.7	No	1969
196.9	100%	--	--	--	582.2	565.3	517.7	No	1969
Model: MAX 50KTL3-XL2									
131.2	25%	--	--	--	486.6	543.9	607.8	No	1312
131.2	50%	--	--	--	497.2	458.9	442.7	No	1312
131.2	100%	--	--	--	535.9	523.3	473.4	No	1312
Supplementary information:									

4.6	TABLE: Harmonics and waveform distortion							P
Model: MAX 75KTL3-XL2								
Harmonic	fundamen tal L1 (A)	% of fundamen tal)	fundamen tal L2 (A)	% of fundamen tal)	fundamen tal L3 (A)	% of fundamen tal)	Harmonic Current Limits (%)	
02	0.2266	0.1150	0.3814	0.1950	0.1367	0.0700	1.0%	
03	0.1721	0.0870	0.2336	0.1190	0.0611	0.0310	4.0%	

IEC61727							
Cl.	Requirement - Test			Result			Verdict
04	0.0808	0.0410	0.2005	0.1020	0.1947	0.0990	1.0%
05	3.2068	1.6260	3.3086	1.6870	3.1664	1.6140	4.0%
06	0.0604	0.0310	0.1152	0.0590	0.0354	0.0180	1.0%
07	1.4608	0.7410	1.5422	0.7870	1.3969	0.7120	4.0%
08	0.1153	0.0580	0.1279	0.0650	0.0400	0.0200	1.0%
09	0.0739	0.0370	0.0337	0.0170	0.0909	0.0460	4.0%
10	0.1132	0.0570	0.1368	0.0700	0.1026	0.0520	0.5%
11	0.9060	0.4590	0.8268	0.4220	0.7467	0.3810	2.0%
12	0.0852	0.0430	0.0994	0.0510	0.0952	0.0490	0.5%
13	0.8945	0.4530	0.9354	0.4770	0.9098	0.4640	2.0%
14	0.0512	0.0260	0.0207	0.0110	0.0606	0.0310	0.5%
15	0.0663	0.0340	0.1000	0.0510	0.0634	0.0320	2.0%
16	0.1032	0.0520	0.0936	0.0480	0.1050	0.0540	0.5%
17	0.7812	0.3960	0.7098	0.3620	0.6849	0.3490	1.5%
18	0.0544	0.0280	0.0094	0.0050	0.0707	0.0360	0.5%
19	0.2055	0.1040	0.2316	0.1180	0.2439	0.1240	1.5%
20	0.0586	0.0300	0.0806	0.0410	0.0215	0.0110	0.5%
21	0.0418	0.0210	0.0337	0.0170	0.0346	0.0180	1.5%
22	0.0145	0.0070	0.0337	0.0170	0.0080	0.0040	0.5%
23	0.3791	0.1920	0.3900	0.1990	0.3871	0.1970	0.6%
24	0.0016	0.0010	0.0067	0.0030	0.0073	0.0040	0.5%
25	0.0967	0.0490	0.0858	0.0440	0.0925	0.0470	0.6%
26	0.0475	0.0240	0.0413	0.0210	0.0308	0.0160	0.5%
27	0.0184	0.0090	0.0134	0.0070	0.0085	0.0040	0.6%
28	0.0467	0.0240	0.0219	0.0110	0.0285	0.0150	0.5%
29	0.0642	0.0330	0.0830	0.0420	0.0721	0.0370	0.6%
30	0.0283	0.0140	0.0387	0.0200	0.0091	0.0050	0.5%
31	0.1072	0.0540	0.0982	0.0500	0.1058	0.0540	0.6%
32	0.0075	0.0040	0.0290	0.0150	0.0159	0.0080	0.5%
33	0.0407	0.0210	0.0262	0.0130	0.0203	0.0100	0.6%
THD	1.967		2.039		1.922		5%
Supplementary information:							

IEC61727			
Cl.	Requirement - Test	Result	Verdict

4.6	TABLE: Harmonics and waveform distortion						P
Model: MAX 50KTL3-XL2							
Harmonic	fundamen tal L1 (A)	% of fundamen tal)	fundamen tal L2 (A)	% of fundamen tal)	fundamen tal L3 (A)	% of fundamen tal)	Harmonic Current Limits (%)
02	0.1085	0.0820	0.2345	0.1790	0.1366	0.1040	1.0%
03	0.0724	0.0550	0.1052	0.0800	0.0461	0.0350	4.0%
04	0.0952	0.0720	0.1341	0.1020	0.1260	0.0960	1.0%
05	1.4840	1.1230	1.5372	1.1700	1.4581	1.1090	4.0%
06	0.0435	0.0330	0.0754	0.0570	0.0588	0.0450	1.0%
07	0.8371	0.6330	0.9378	0.7140	0.8570	0.6520	4.0%
08	0.0433	0.0330	0.0692	0.0530	0.0332	0.0250	1.0%
09	0.0361	0.0270	0.0271	0.0210	0.0675	0.0510	4.0%
10	0.0115	0.0090	0.0566	0.0430	0.0654	0.0500	0.5%
11	0.5575	0.4220	0.5276	0.4020	0.4949	0.3770	2.0%
12	0.0673	0.0510	0.0855	0.0650	0.0683	0.0520	0.5%
13	0.4533	0.3430	0.4605	0.3510	0.4722	0.3590	2.0%
14	0.0546	0.0410	0.0302	0.0230	0.0387	0.0290	0.5%
15	0.0280	0.0210	0.0137	0.0100	0.0343	0.0260	2.0%
16	0.0411	0.0310	0.0446	0.0340	0.0077	0.0060	0.5%
17	0.6799	0.5140	0.6253	0.4760	0.6337	0.4820	1.5%
18	0.0280	0.0210	0.0309	0.0240	0.0342	0.0260	0.5%
19	0.1276	0.0970	0.1231	0.0940	0.1045	0.0800	1.5%
20	0.0406	0.0310	0.0573	0.0440	0.0133	0.0100	0.5%
21	0.0252	0.0190	0.0189	0.0140	0.0069	0.0050	1.5%
22	0.0167	0.0130	0.0219	0.0170	0.0280	0.0210	0.5%
23	0.2891	0.2190	0.2797	0.2130	0.2477	0.1880	0.6%
24	0.0251	0.0190	0.0264	0.0200	0.0378	0.0290	0.5%
25	0.0961	0.0730	0.1082	0.0820	0.0522	0.0400	0.6%
26	0.0131	0.0100	0.0431	0.0330	0.0266	0.0200	0.5%
27	0.0304	0.0230	0.0084	0.0060	0.0198	0.0150	0.6%
28	0.0420	0.0320	0.0503	0.0380	0.0717	0.0550	0.5%
29	0.0451	0.0340	0.0461	0.0350	0.0670	0.0510	0.6%

Page 15 of 22

Report No. 22000000000000000000

IEC61727							
Cl.	Requirement - Test			Result			Verdict
30	0.0197	0.0150	0.0246	0.0190	0.0189	0.0140	0.5%
31	0.0624	0.0470	0.1120	0.0850	0.0753	0.0570	0.6%
32	0.0039	0.0030	0.0193	0.0150	0.0355	0.0270	0.5%
33	0.0189	0.0140	0.0162	0.0120	0.0378	0.0290	0.6%
THD	1.530		1.596		1.507		5%
Supplementary information:							

4.7	TABLE: Power factor							P
Model: MAX 75KTL3-XL2								
	Input			Output				
No	Voltage (V d.c.)	Curre nt (A d.c.)	Power (W)	Voltage (V a.c.)	Current (A a.c.)	Power (W)	Power factor (+/-)	Rated output (V.A)
1	362.38	44.59	16155.43	126.32	40.16	15163.87	0.9963	(20±5)%
2	362.15	66.08	23929.70	126.51	60.00	22707.25	0.9972	(30±5)%
3	361.78	87.82	31769.51	126.70	79.81	30263.72	0.9977	(40±5)%
4	127.04	99.78	12650.93	126.88	99.40	37755.57	0.9979	(50±5)%
5	361.15	131.34	47431.11	127.07	118.83	45212.32	0.9981	(60±5)%
6	360.94	153.26	55315.67	127.26	138.35	52717.43	0.9981	(70±5)%
7	360.57	175.43	63254.93	127.44	157.83	60225.20	0.9980	(80±5)%
8	360.26	197.81	71260.83	127.64	177.29	67762.75	0.9982	(90±5)%
9	360.00	220.18	79262.55	127.84	196.57	75255.32	0.9982	(100±5)%
Supplementary information:								
Power factor with “+” indicating leading and “-” indicating lagging.								

4.7	TABLE: Power factor							P
Model: MAX 50KTL3-XL2								
	Input			Output				
No	Voltage (V d.c.)	Curre nt (A d.c.)	Power (W)	Voltage (V a.c.)	Current (A a.c.)	Power (W)	Power factor (+/-)	Rated output (V.A)
1	362.62	29.90	10841.99	126.19	26.54	9994.20	0.9947	(20±5)%
2	362.38	44.33	16063.72	126.33	39.93	15079.91	0.9965	(30±5)%

IEC61727								
Cl.	Requirement - Test					Result		Verdict
3	362.19	58.82	21304.75	126.45	53.11	20088.39	0.9970	(40±5)%
4	361.95	73.20	26493.21	126.58	66.31	25113.15	0.9974	(50±5)%
5	361.76	87.67	31715.18	126.71	79.46	30135.95	0.9977	(60±5)%
6	361.62	102.15	36939.44	126.84	92.61	35160.84	0.9978	(70±5)%
7	361.43	116.69	42175.56	126.97	105.70	40180.35	0.9979	(80±5)%
8	361.24	131.35	47446.70	126.89	119.01	45215.89	0.9981	(90±5)%
9	361.01	145.54	52541.17	127.01	131.64	50063.54	0.9982	(100±5)%
Supplementary information: Power factor with “+” indicating leading and “-“ indicating lagging.								

IEC61727			
Cl.	Requirement - Test	Result	Verdict

5.2.1 & 5.4		TABLE: Under-and over-voltage trip settings and reconnection test						P
(1) Under voltage disconnection procedure								
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)	
127	75K	107.95	108.0	0.10	4	106.98	1.49	
Rated output voltage (V)	Output power (VA)	Required min. voltage (V)	Value of PCE trip settings (V)	Ratio of decreased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)	
127	75K	63.5	63.0	0.10	0.1	63.90	0.063	
(2) Under voltage reconnection procedure								
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)			Reconnection time (s)		
0.10			>108			81.2		
(3) Over voltage disconnection procedure								
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)	
127	75K	139.7	140	0.10	4	139.7	1.50	
Rated output voltage (V)	Output power (VA)	Required max. voltage (V)	Value of PCE trip settings (V)	Ratio of increased (V / s)	Interval time (s)	Measured tripped voltage (V)	Measured disconnection time (s)	
127	75K	171.5	172	0.10	0.1	172.2	0.032	
(4) Over voltage reconnection procedure								
Ratio of voltage rapidly decreased (V / s)			Reconnection voltage (V)			Reconnection time (s)		
0.10			<139			80.90		
Supplementary information:								
Tested on model MAX 75KTL3-XL2								

IEC61727			
Cl.	Requirement - Test	Result	Verdict

5.2.2 & 5.4		TABLE: Over/under frequency trip settings and reconnection test						P
(1) Under frequency disconnection procedure								
Rated output frequency (Hz)	Output power (VA)	Required min. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of decreased (Hz / s)	Interval time (s)	Measured tripped frequency (Hz)	Measured disconnection time (s)	
60	75K	59	59	0.01	0.3	59.01	0.185	
(2) Under frequency reconnection procedure								
Ratio of frequency rapidly decreased (Hz / s)			Reconnection frequency (Hz)			Reconnection time (s)		
0.01			>59			82.2		
(3) Over frequency disconnection procedure								
Rated output frequency (Hz)	Output power (VA)	Required max. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of increased (Hz / s)	Interval time (s)	Measured tripped frequency (Hz)	Measured disconnection time (s)	
60	75K	61	61	0.01	0.3	60.96	0.182	
(4) Over frequency reconnection procedure								
Ratio of frequency rapidly decreased (Hz / s)			Reconnection frequency (Hz)			Reconnection time (s)		
0.01			<61			80.8		
Supplementary information:								
Tested on model MAX 75KTL3-XL2 with frequency 60Hz								

IEC61727			
Cl.	Requirement - Test	Result	Verdict

5.2.2 & 5.4		TABLE: Over/under frequency trip settings and reconnection test					P
(1) Under frequency disconnection procedure							
Rated output frequency (Hz)	Output power (VA)	Required min. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of decreased (Hz / s)	Interval time (s)	Measured tripped frequency (Hz)	Measured disconnection time (s)
50	75K	49	49	0.01	0.3	49.01	0.176
(2) Under frequency reconnection procedure							
Ratio of frequency rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)		
0.01			>49		79.0		
(3) Over frequency disconnection procedure							
Rated output frequency (Hz)	Output power (VA)	Required max. frequency (Hz)	Value of PCE trip settings (Hz)	Ratio of increased (Hz / s)	Interval time (s)	Measured tripped frequency (Hz)	Measured disconnection time (s)
50	75K	51	51	0.01	0.3	50.99	0.193
(4) Over frequency reconnection procedure							
Ratio of frequency rapidly decreased (Hz / s)			Reconnection frequency (Hz)		Reconnection time (s)		
0.01			<51		79.0		
Supplementary information:							
Tested on model MAX 75KTL3-XL2 with frequency 50Hz							

IEC61727			
Cl.	Requirement - Test	Result	Verdict

5.3		TABLE: tested condition and run-on time							P
Model: Tested on model MAX 75KTL3-XL2 with frequency 50Hz									
No.	P _{EUT} (% of EUT rating)	Reactive load (% of normal)	P _{AC}	Q _{AC}	Run-on time(ms)	P _{EUT} (KW)	Actual Q _f (Var)	V _{DC} (V)	Which load is selected to be adjusted (R or L)
Test condition A									
1	100	100	0	0	459.5	75.11	1.00	800	/
2	100	100	-5	-5	332.5	75.11	0.98	800	/
3	100	100	-5	0	279.5	75.11	0.95	800	/
4	100	100	-5	+5	305.0	75.11	0.93	800	/
5	100	100	0	-5	401.0	75.11	1.03	800	/
6	100	100	0	+5	311.5	75.11	0.98	800	/
7	100	100	+5	-5	258.5	75.11	1.08	800	/
8	100	100	+5	0	279.5	75.11	1.06	800	/
9	100	100	+5	+5	157.5	75.11	1.03	800	/
Test condition B									
10	66	66	0	0	299.5	49.68	1.00	520	/
11	66	66	0	-5	196.0	49.68	1.03	520	L
12	66	66	0	-4	292.0	49.68	1.02	520	L
13	66	66	0	-3	287.5	49.68	1.02	520	L
14	66	66	0	-2	243.5	49.68	1.01	520	L
15	66	66	0	-1	242.0	49.68	1.01	520	L
16	66	66	0	1	308.0	49.68	0.99	520	L
17	66	66	0	2	464.0	49.68	0.99	520	L
18	66	66	0	3	415.5	49.68	0.98	520	L
19	66	66	0	4	409.5	49.68	0.98	520	L
20	66	66	0	5	311.5	49.68	0.97	520	L
Test condition C									
21	33	33	0	0	838.0	24.81	1.00	309	/
22	33	33	0	-5	529.0	24.81	1.03	309	L
23	33	33	0	-4	668.0	24.81	1.02	309	L
24	33	33	0	-3	832.0	24.81	1.02	309	L
25	33	33	0	-2	652.0	24.81	1.01	309	L
26	33	33	0	-1	770.0	24.81	1.01	309	L
27	33	33	0	1	716.0	24.81	0.99	309	L
28	33	33	0	2	600.0	24.81	0.99	309	L
29	33	33	0	3	858.0	24.81	0.98	309	L
30	33	33	0	4	612.0	24.81	0.98	309	L
31	33	33	0	5	460.0	24.81	0.97	309	L

IEC61727			
Cl.	Requirement - Test	Result	Verdict

Supplementary information:

For test condition A:

If any of the recorded run-on times are longer than the one recorded for the rated balance condition, then the non-shaded parameter combinations also require testing.

For test condition B and C:

If run-on times are still increasing at the 95 % or 105 % points, additional 1 % increments is taken until run-on times begin decreasing.

IEC61727			
Cl.	Requirement - Test	Result	Verdict

5.3		TABLE: tested condition and run-on time							P
Model: Tested on model MAX 75KTL3-XL2 with frequency 60Hz									
No.	P _{EUT} (% of EUT rating)	Reactive load (% of normal)	P _{AC}	Q _{AC}	Run-on time(ms)	P _{EUT} (KW)	Actual Q _f (Var)	V _{DC} (V)	Which load is selected to be adjusted (R or L)
Test condition A									
1	100	100	0	0	730.0	75.11	1.00	800	/
2	100	100	-5	-5	330.0	75.11	0.97	800	/
3	100	100	-5	0	484.0	75.11	0.95	800	/
4	100	100	-5	+5	414.0	75.11	0.93	800	/
5	100	100	0	-5	322.0	75.11	1.03	800	/
6	100	100	0	+5	256.0	75.11	0.98	800	/
7	100	100	+5	-5	260.0	75.11	1.08	800	/
8	100	100	+5	0	648.0	75.11	1.06	800	/
9	100	100	+5	+5	588.0	75.11	1.04	800	/
Test condition B									
10	66	66	0	0	335.5	49.68	1.00	520	/
11	66	66	0	-5	259.0	49.68	1.03	520	L
12	66	66	0	-4	327.0	49.68	1.02	520	L
13	66	66	0	-3	373.5	49.68	1.02	520	L
14	66	66	0	-2	327.5	49.68	1.01	520	L
15	66	66	0	-1	285.5	49.68	1.01	520	L
16	66	66	0	1	313.0	49.68	0.99	520	L
17	66	66	0	2	629.0	49.68	0.99	520	L
18	66	66	0	3	327.0	49.68	0.98	520	L
19	66	66	0	4	411.0	49.68	0.98	520	L
20	66	66	0	5	299.0	49.68	0.97	520	L
Test condition C									
21	33	33	0	0	530.0	24.81	1.00	309	/
22	33	33	0	-5	134.5	24.81	1.03	309	L
23	33	33	0	-4	192.5	24.81	1.02	309	L
24	33	33	0	-3	178.5	24.81	1.02	309	L
25	33	33	0	-2	226.5	24.81	1.01	309	L
26	33	33	0	-1	234.5	24.81	1.01	309	L
27	33	33	0	1	235.5	24.81	0.99	309	L
28	33	33	0	2	153.5	24.81	0.99	309	L
29	33	33	0	3	182.5	24.81	0.98	309	L
30	33	33	0	4	176.5	24.81	0.98	309	L
31	33	33	0	5	175.5	24.81	0.97	309	L

IEC61727			
Cl.	Requirement - Test	Result	Verdict

Supplementary information:

For test condition A:

If any of the recorded run-on times are longer than the one recorded for the rated balance condition, then the non-shaded parameter combinations also require testing.


For test condition B and C:

If run-on times are still increasing at the 95 % or 105 % points, additional 1 % increments is taken until run-on times begin decreasing.

Appendix 1: Photos



Top view of the unit



Back view of the unit

Appendix 1: Photos




PV Input Terminal view




Side view

Appendix 1: Photos



Internal view



Internal view

--- End of test report---